



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

<u>Pipe Specification</u>	<u>Pipe Schedule</u>	<u>Pipe Size</u>
ASTM A795 / A795M	Schedule 10	3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, 12 inch NPS
ASTM A53 / A53M	Schedule 40	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4, 5, 6, 8, 10, 12 inch NPS
EN 10255	Medium	26.9, 33.7, 42.4, 48.3, 60.3, 76.1, 88.9, 114.3, 139.7, 165.1 mm NPS

Prepared for:

Çayırova Boru San. Ve Tic. A.S.
Osmangazi Mah. Aşıroğlu Cad. No: 170
Darıca/ KOCAELİ, 41700
Turkey

Manufactured at:

Çayırova Boru San. Ve Tic. A.S.
Osmangazi Mah. Aşıroğlu Cad. No: 170
Darıca/ KOCAELİ, 41700
Turkey

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056333

Approval Granted: July 23, 2018

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager of Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group